

Office of the Revisor of Statutes

Administrative Rules



TITLE: Adopted Permanent Rules Governing Fluoridation of Municipal Water Supplies

AGENCY: Department of Health

REVISOR ID: R-4458

MINNESOTA RULES: Chapter 4720



The attached rules are approved for
filing with the Secretary of State

A handwritten signature in cursive script, reading "Sandy Glass-Sirany".

Sandy Glass-Sirany
Senior Assistant Revisor

002908

10/14/19

REVISOR

SGS/EH

AR4458

1.1 **Department of Health**

1.2 **Adopted Permanent Rules Governing Fluoridation of Municipal Water Supplies**

1.3 **4720.0030 FLUORIDATION.**

1.4 *[For text of subpart 1, see Minnesota Rules]*

1.5 Subp. 2. **Fluoride content.** The fluoride content of the water shall be controlled to
1.6 maintain an average concentration of 0.7 milligrams per liter; the concentration shall be
1.7 neither less than 0.5 milligrams per liter nor more than 0.9 milligrams per liter.

1.8 *[For text of subparts 3 to 6, see Minnesota Rules]*

February 18, 2020

VIA EMAIL ONLY

Nancy Breems
Secretary of State, Elections Division
180 State Office Building
100 Rev Dr Martin Luther King Jr Blvd
St. Paul, Minnesota 55155-1299
official.documents@state.mn.us

**Re: *In the Matter of the Department of Health's Proposed Rules
Governing Water Fluoridation*
OAH 5-9000-36418; Revisor R-4458**

Dear Ms. Breems:


Enclosed for filing is an electronic copy of the above-entitled adopted rules.

Please send the agency copy of the rules to:

Anita Smith
Department of Health
PO Box 64975
Saint Paul, MN 55164

If you have any questions, please contact me at (651) 361-7881, at anne.laska@state.mn.us; or via fax at (651) 539-0310.

Sincerely,



ANNE LASKA
Legal Assistant

Enclosures

cc: Anita Smith (via email)